

### AZ VEE Working Group Issues List

#	Issue	Issue Date/Issue ID by	Discussion	Status/ Status Date
1	<p>Reference VEE Strike through Document 3.3.2)</p> <p>Pass/Fail Criteria: How will the MRSP know the time meter has failed Time Tolerance for three (3) consecutive months; requires the meter to be physically inspected and or tested?</p> <p>How will this be enforced?</p> <p>Can a code be used on 867 for this in order to track this?</p>	05/25/00 – VEE Group	This is listed in the VEE document and the group would like to review how this is being done enforce etc. Action items set for this issue	Pending
2	Are there formal procedures for meter testing and exchange of data?	05/25/00 – VEE Group	Group is not clear if these are in place and if the data exchange is formalized	Pending
3	Can an external meter device be used to record pulses? (Meter would still have the display required (??) But the read is not encoded to the recorder.	05/25/00 – VEE Group	Group is not sure if this question has been addressed	Pending
4	How does the MRSP keep at an interval level the algorithm used to estimate?	05/25/00 – VEE Group	This is in the VEE document and not sure how the MRSP manages this information	Pending
5	Should the UDC pass the customers “irregular” load status to the ESP?	05/25/00 – VEE Group	This information is not known by the ESP the VEE rule editing in progress provides the MRSP this option, unresolved	Pending
6	<p><b>Cumulative Register Reading</b></p> <ul style="list-style-type: none"> <li>• If the meter is calibrated to current ACC administrative code standards, this would be sufficient for billing, except for TOU type rates.</li> <li>• Suggestion that all meters have cumulative register capabilities – this would be the first step and the best validation procedure.</li> <li>• Compare cumulative to sum of intervals and if it falls within an acceptable percentage, stop. If for some reason the metering equipment failed, then provide some means of estimation.</li> </ul>	05/25/00 – VEE Group	This in response to solicited comments on the VEE Rules and Procedures	Pending
7	Create a Strawman for Section 4.2 of the VEE Rules (Selecting Reference Days for Estimation)	6/20/00 – VEE Group	A strawman will be created in response to the days listed in the current VEE being incorrect in regards to Arizona standards	Pending
8	Rewrite Section 4.3 of the VEE Rules (Correcting Data Problems Attributable to Metering Problems)	6/20/00 – VEE Group	Discussion of the section resulted in a request for a rewrite due to wording	Pending